

3/19/09

To Whom It May Concern:

Eiko linear fluorescent lamps have been tested with the mercury Toxicity Characteristic Leaching Procedure (TCLP) and passed, being below the limit of 0.200 milligrams per liter of leachate.

Dispose of per your state or local regulations for TCLP-compliant lamps.

Here is a website for regulations: www.lamprecycle.org.

Regards,

Rod Phillips
QA Manager
Eiko, Ltd.